

## Details of Fire Fighting Facility.

This is certify that project RELATION by MAA DURGA ENTERPRISE According to Jharkhand building bye-laws 2016 clause No. 7, sub clause No. 7.5 for all building with a height of 16m and Above or covered area at any floor within premises more than 500sqm NOC from Fire service Department shall be obtain so project is Not applicable for the fire fighting system because the project is less than 16m and plinth area less than 500sqm.

**MAA DURGA ENTERPRISE**

  
Proprietor

